



Shenzhen Hongcai Testing Technology Co., Ltd.

CE Certificate of Conformity

Certification number: HCT18IR-5307S

Report number: HCT18IR-5307S

Shenzhen Hongcai Testing Technology Co., Ltd. hereby declares that testing has been completed and reports have been generated for:

Applicant: Magnizon power systems FZE
Address: JAFZA LB11, 1st floor, Office 32, Jebel Ali Free Zone, Dubai-U.A.E
Manufacturer: Magnizon power systems FZE
Address: JAFZA LB11, 1st floor, Office 32, Jebel Ali Free Zone, Dubai-U.A.E
Product: UPS1-3KVA
Trade Mark: MAGNIZON
Model: MU1000RM2U, MU2000RM2U, MU3000RM2U
Rating: Input:220V~240V, 15A, 3000W, 50/60Hz
Output:220V~240V, 13.6A, 2700W, 50/60Hz

And, in accordance with the following applicable directives:

2014/35/EU Low Voltage Directive

That this product has been assessed against the following applicable standards;

EN 62040-1:2008+A1:2013

LVD

Uninterruptible power systems (UPS) –

Part 1: General and safety requirements for UPS

Therefore, Shenzhen Hongcai Testing Technology Co., Ltd. hereby acknowledges that the applicant may issue a DECLARATION of CONFORMITY and apply the CE marking in accordance with European Union Rules.

Attestation by:

Tony Wu



Date of Issued: October 12, 2018

1-2/F., Building C, Shuanghuan Xin Yi Dai Hi-Tech Industrial Park, No.8 Baoqing Road, Baolong Industrial Zone,
Longgang District, Shenzhen City, P.R.China

Tel:+86-755-86337020 Fax:86-755-86337028 <http://www.hct-test.com>