



EC Declaration of Conformity

We, the undersigned, declare under our sole responsibility that the equipment Specified below conforms to the following standards and directives:

Type of Equipment: **On-line double conversion technology UPS**

Series Number: **Rack mount series**
Models: **MU6000RM3U, MU10KRM3U**

Safety: EN62040-1: 2003	
Conducted Emission: EN50091-2	Class B
Radiated Emission: EN50091-2	Class B
Harmonic Current: EN61000-3-2	
Voltage Fluctuations and Flicker:	EN61000-3-3
EMS: IEC61000-4-2(ESD)	Level 4
IEC61000-4-3(RS)	Level 3
IEC61000-4-4(EFT)	Level 4
IEC61000-4-5(lightning surge)	Level 4

Manufacturer Name and Address:

Magnizon Power Systems FZE
Dubai-U.A.E
PO:263819

Bathala .H
Regulatory Engineer
April 9, 2015

Test Report

Product Information	Product Name	UPS	Sales Number		
	Model	MU6000RM3U			
	Work Order Number		Machine Serial Number		
Testing Items	Testing Appearance				
	Serial Number	Testing Items		Results Judgement	
	1	Checking if the surface scratches, paint off or not		√	
	2	Checking if silk print content, color and location is correct or not		√	
	3	Checking whether the contents of the stickers, the location is correct or not		√	
	4	Checking if the switch is flexible or not		√	
	5	Checking if the product screws are installed as required or not		√	
	6	Checking if fan and fan installation direction is correct or not		√	
	7	Checking if the information and accessories attached randomly are complete or not		√	
	Testing Function				
	Serial Number	Testing Items		Standard Value	Measured Value
	1	Test of the line mode parameter	High voltage switching point	275±7V	275
	2		Low voltage switching point	120±7V	120
	3		Positive BUS	360±10V	362
	4		Negative BUS	360±10V	363
5	Full load output voltage		220±1%V	218	
6	105% overload alarm		/	√	

7	Charging test project	Charging voltage	218±2V	218
8		Charging current	1±0.5A	1.1A
9	Test battery model parameters	Full load output voltage	220±1%V	221
10		The output frequency	50±0.2Hz	50
11		Positive BUS	360±10V	363
12		Negative BUS	360±10V	364
13	A functional test	Communication function test	/	✓
14		Maintenance bypass function	/	✓

Testing Results	Qualified	<input checked="" type="checkbox"/>	Unqualified

Test Report

Product Information	Product Name	UPS	Sales Number		
	Model	MU10000RM3U			
	Work Order Number		Machine Serial Number		
Testing Items	Testing Appearance				
	Serial Number	Testing Items		Results Judgement	
	1	Checking if the surface scratches, paint off or not		✓	
	2	Checking if silk print content, color and location is correct or not		✓	
	3	Checking whether the contents of the stickers, the location is correct or not		✓	
	4	Checking if the switch is flexible or not		✓	
	5	Checking if the product screws are installed as required or not		✓	
	6	Checking if fan and fan installation direction is correct or not		✓	
	7	Checking if the information and accessories attached randomly are complete or not		✓	
	Testing Function				
	Serial Number	Testing Items		Standard Value	Measured Value
	1	Test of the line mode parameter	High voltage switching point	275±7V	276
	2		Low voltage switching point	120±7V	122
3	Positive BUS		360±10V	364	
4	Negative BUS		360±10V	363	
5	Full load output voltage		220±1%V	219	

	6		105% overload alarm	/	√
	7	Charging test project	Charging voltage	218±2V	217
	8		Charging current	1±0.5A	1.1A
	9	Test battery model parameters	Full load output voltage	220±1%V	221
	10		The output frequency	50±0.2Hz	50
	11		Positive BUS	360±10V	363
	12		Negative BUS	360±10V	362
	13	A functional test	Communication function test	/	√
	14		Maintenance bypass function	/	√

Testing Results	<table border="1" style="width: 100%;"> <tr> <td style="text-align: center;">Qualified</td> <td style="text-align: center;">Unqualified</td> </tr> </table>	Qualified	Unqualified	<input checked="" type="checkbox"/>
Qualified	Unqualified			

Checker/Date: liu xuehua20190409 jun20190409

Checking/Date: luo

Notice: Numerical value can be quantified, should fill in the value in the special location; can not be quantified, in the specified location designated "√" unqualified "×"; untested project "/".